# Performance Characterization of a Vanadium Redox Flow Battery

Luis Fialho<sup>1</sup>, Tomás Fartaria<sup>1</sup>, Manuel Collares Pereira<sup>1</sup>
<sup>1</sup> ST Renewable Energies Chair, Universidade de Évora, Portugal


## **Vanadium Redox Flow Battery**


Specification	Value
Number of cells	40
Tank volume	2x1800 l
Maximum current	200 A
Nominal Power	5 kW
Storage capacity	60 kWh
Battery inverters nominal power	3x2.4 kW





# Test 1 - Full Cycle Charge/Discharge Efficiency cell






### Test 2 - State of Charge (SOC) vs Voltage of reference

#### **Conclusions:**

The tests performed are in accordance with the specifications provided by the battery manufacturer.

The inverters voltage range limit the battery capacity to 60 kWh.

The reference cell voltage is not affected by the battery charge/discharge state. The reference cell allowed a precise SOC measurement.











For more information see also poster "Validation of a Energy Management Strategy for a BIPV System with a Vanadium Battery Demonstrator".









